Installation Guidance

I55 sensor kitchen mixer

Bridgepoint SKU IDI55D0-07000 | Idral code I55D0-07000

Installation sequence

1. Have a qualified installer prepare the connections using the manufacturer drawing and the instructions supplied with the product. Purge the supply pipes before connection and provide suitable water filtration.

2. Align the tap with the deck opening, fit the gasket and secure the mounting kit. Connect hot and cold supplies to the marked inlets without twisting or stretching the flexible hoses. Keep service components accessible.

3. Connect the supplied mains power unit according to the exact model instructions. Have qualified personnel make the 230 V connection and keep electrical components protected from water.

4. Open the supplies and check for leaks. Set the mixed-water temperature and test sensor ON/OFF control by placing a hand 3-8 cm from the sensor. Confirm the 60-second continuous-flow safety stop.

5. Test the manual by-pass using the fitted cartridge control. Check the swivel spout moves freely.

Important

Product operating range: 1-8 bar; inlet water temperature 5-70 °C. The automatic hygiene flush occurs 24 hours after the last activation.

Source: Idral product technical data and product information. This is summary guidance; use the full model instructions supplied with the product for complete assembly, electrical connection and service procedures.