I55 sensor kitchen mixer with pull-out spray

Bridgepoint SKU IDI55D0-08000 | Idral code I55D0-08000

Routine care

Clean exposed surfaces with water and mild soap. Avoid aggressive or abrasive cleaners and dry with a soft cloth.

Isolate the water supply before dismantling or replacing components. Purge the upstream pipes after a shutdown before returning the unit to service.

Keep the sensor window clean. Check inlet filters and non-return valves where fitted if the flow falls. Use the matching manufacturer procedure for cleaning internal parts.

Use the specified 6 V CRP2 lithium battery when replacement is needed. Keep the battery compartment dry and dispose of the used battery appropriately.

After service, test sensor ON/OFF operation, mixing control, automatic closure and leak tightness.

Service

Use the product instructions supplied with the unit for complete dismantling and service procedures.

The technical sheet identifies the control functions; use the full I55 model instructions for internal cartridge and solenoid servicing.

Source: Idral product technical data and product information. This is summary guidance; use the full model instructions supplied with the product for complete assembly, electrical connection and service procedures.